



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NV-5180BO0344

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas and water supply <i>Produkte der Gas- und Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	SEAL FOR LIFE Industries BV Nijverheidsstraat 13, B-2260 Westerlo
Distributor <i>Vertreiber</i>	SEAL FOR LIFE Industries BV Nijverheidsstraat 13, B-2260 Westerlo
Product Category <i>Produktart</i>	Greasing and sealing materials: Protection tape against corrosion (5180)
Product description <i>Produktbezeichnung</i>	Protection bandage against corrosion
Model <i>Modell</i>	Polyken 942/955EN
Test reports <i>Prüfberichte</i>	Laboratory control test: 21-01287-KP02- from 08.07.2022 (EBI) Type testing: 18/194/5180/1 from 29.05.2019 (EBI)
Test basis <i>Prüfgrundlagen</i>	DIN EN 12068 (01.03.1999)

Date of Expiry / File No. 10.07.2028 / 23-0227-GNV
Ablaufdatum / Aktenzeichen

02.05.2023 Kir A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Polyken 942/955EN	Stress class: C Permanent operating temperature: max. 50 °C Designation according to standard: Coating EN 12068-C 50	

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

Cold applied corrosion protection tape with 4 layers wrapped on top of primer coat